

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 6911-0065:135 Page 1 of 1

CATEGORY: Voice Communication System Control Unit

LISTEE: Faraday Inc, 805 South Maumee St., Tecumseh MI 49286  
Contact: Steve A. Blohm (517) 423-2111

DESIGN: Models MVP 500 and 860 emergency voice evacuation, relocation, and paging system. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

|                                     |                             |
|-------------------------------------|-----------------------------|
| MVP5-CX/15095                       | Comment Equipment Board     |
| SP-500/15063                        | Speaker Module              |
| ST-500/15064                        | Strobe Module               |
| MVP5-CH/15090                       | Common Equipment Chassis    |
| MVP5-PS/PS-MAIN/MVP5-AP/15098/15099 | Power Supply                |
| MVP5-AM/15096                       | Amplifier Driver            |
| DM-501/15065                        | Pre-Recorded Message Module |
| MVP5-CB/15091                       | Enclosure                   |

RATING: Primary 120 VAC, 2A per power supply assembly  
Secondary: 24 VDC, 6.5 – 26 Ah capacity

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as voice communication/evacuation/relocation/paging system for use as a stand alone audio unit or with separately listed and electrically compatible fire alarm control unit.

XLF: 6911-1393:104

02-29-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MAY 15, 2001**

*Listing Expires **June 30, 2002***

Authorized By:

**BEN HO**, Supervising Deputy  
Program Manager